

ADDENDUM NO. 2

DATE: October 27, 2015
FROM: Village of Villa Park Public Works Department
TO: All Potential Bidders
PROJECT: **East Park Boulevard Improvement Project**

The Bidding Documents for the subject project are hereby amended as follows. Please indicate your acknowledgment of this Addendum by filling out the attached Acknowledgment Form and returning it with your Bid.

CHANGE THE FOLLOWING ITEM(S) IN THE PLANS:

ON PLAN SHEET 4 OF 36, "GENERAL NOTES":

DELETE:

11. Existing traffic signs which conflict with Contractor's operations shall be removed and stored by Contractor at a safe and secure location until Engineer deems it desirable to have them reinstalled. The Contractor shall reinstall these signs at locations directed by the Engineer. The exception to this shall be stop signs, which shall remain in place. The Contractor shall maintain and/or relocate as necessary. This work shall be considered incidental to the contract.

INSERT:

11. Existing signs which conflict with Contractor's operations shall be removed and stored by Contractor at a safe and secure location until Engineer deems it desirable to have them reinstalled. The Contractor shall reinstall these signs at locations directed by the Engineer. This will apply to all signs regardless of whether they are located on public rights-of-way, on easements, or on private property, and will also apply to all signs at the Montessori Children's Academy (MCA) at 706 East Park Boulevard. The exception to this shall be stop signs, which shall remain in place, and which Contractor shall maintain and/or relocate as determined necessary by the Engineer. Any signs which are damaged during construction or while stored by Contractor will be replaced and reinstalled by the Contractor. This work shall be considered to be included in the cost of the contract.

CHANGE THE FOLLOWING ITEM(S) IN THE SPECIFICATIONS:

IN THE SPECIAL PROVISION “PRECAST CONCRETE JUNCTION CHAMBERS”:

INSERT A NEW PARAGRAPH BEFORE “BASIS OF PAYMENT”:

The existing segmented-tile sewer on which the precast concrete junction chamber or 7'-diameter manhole is to be installed is a combined sewer with substantial flow. Contractor will perform any bypass pumping and dewatering which are necessary for installation of the junction chamber or manhole or which are deemed necessary by Engineer. The Village will, upon request from Contractor, permit Contractor to divert upstream sewage flows at two locations: a diversion structure located in the south parkway of the intersection of Park Boulevard and Monterey Avenue; and a manhole and diversion structure located in the southeast parkway of the intersection of Highland Avenue and Riverside Drive. If Contractor makes such request, Contractor will provide all labor and materials necessary to divert flows at those locations, and will return those locations to their prior condition immediately following completion of the work. Contractor will obtain approval of the methods for diverting flows from Engineer or the Village prior to implementation. Contractor will only divert flows under the direct supervision of the Engineer or the Village. Contractor will still perform any bypass pumping and dewatering which are necessary for installation of the junction chamber or manhole even if upstream flows are diverted. All labor, materials and other costs related to bypass pumping, dewatering, and implementation and removal of diversion methods will be included in the cost of PRECAST CONCRETE JUNCTION CHAMBER NO. 1 and MANHOLES, TYPE A, 7' DIA., WITH TYPE 1 FRAME, CLOSED LID (SPECIAL).

IN THE SPECIAL PROVISION “WATER DISTRIBUTION”:

INSERT A NEW PARAGRAPH AT THE END OF THE SPECIAL PROVISION:

All materials used in the construction of water system improvements as a part of this project shall be produced in the United States.

**ADDENDUM NO. 2
ACKNOWLEDGMENT FORM**

I/We hereby acknowledge receipt of the following documents pertaining to **ADDENDUM No. 2** to the Bidding Documents for the Village of Villa Park's **EAST PARK BOULEVARD IMPROVEMENT PROJECT**.

Addendum No. 2

2 pages

Name: _____

Title: _____

Company: _____

Signature: _____

Date: _____